ARISH BABU R.R. M.Sc.,

Jalashakthi Ground Water & Borewell Consultant

35/6, Kiran Complex, Opp. Mangalore Independent College,
Ullala Main Road, Muneshwara Nagar, Jnanabharathi Post,
Bangalore - 560 056.

Mobile : 99801 94377
98443 72004
E-mail : arishbabu11@gmail.com

GROUND WATER INVESTIGATION / YIELD REPORT



No.: KA/13/05/15

Date : 06/05/2017

Name & Adress : A.E.E. SHETTYHALLI
W/12 SHETTYHalli SUB DIVISION
BANGALORE

Purpose of Ground Water : Domestic / [Drinking]

Ground Water Potential : Good

Site Location : Pillappa Circle Near Govt School/ ~~ABBIGERE~~

Topography : Plain Terrian

Soil : BROWNISH

Rock below the soil : Granite & Chist (Metamorphic Rock)

Water Striking Levels					
	1st Source	2nd Source	3rd Source	Casing	Yield
Point # 1	550-650 Ft.	750-800 Ft.	950-1110 Ft.	150-180 Ft.	1400/150 Gals/Hr.
Point # 2	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 3	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 4	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 5	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 6	Ft.	Ft.	Ft.	Ft.	Gals/Hr.

Note : Although the best site for drilling has been suggested. NO GUARANTEE of success can be given and we will not be liable in any way for any loss to the party in respect of the well drilled at the recommended being failure.

AE-12

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ
ಎಸ್.ಎಂ ರಸ್ತೆ, ರವೀಂದ್ರನಗರ, ಬೆಂಗಳೂರು

Rec'd. N.I.C.
-Ack

RRA

(ARISH BABU R.R.)
Consultant Geologist / Diviner

ARISH BABU R.R. M.Sc.,

Jalashakthi Ground Water & Borewell Consultant

35/6, Kiran Complex, Opp. Mangalore Independent College,
Ullala Main Road, Muneshwara Nagar, Jnanabharathi Post,
Bangalore - 560 056.

Mobile : 99801 94377
98443 72004
E-mail : arishbabu11@gmail.com

GROUND WATER INVESTIGATION / YIELD REPORT



No.: KA/17/05/15

Date : 06/05/2017

Name & Adress : A.E.E- SHETTYHALLI
D/12, SHETTYHALLI Sub Division
BANGALORE

Purpose of Ground Water : Domabic (Drinking water)

Ground Water Potential : GOOD

Site Location : Sapna Layout (Abbigere)

Topography : Plain Terrian

Soil : BROWNISH

Rock below the soil : Granitic schist (Metamorphic Rock)

Water Striking Levels

	1st Source	2nd Source	3rd Source	Casing	Yield
Point # 1	600-700 Ft.	800-900 Ft.	1050-1150 Ft.	190-210 Ft.	2100/2388 Gals/Hr.
Point # 2	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 3	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 4	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 5	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 6	Ft.	Ft.	Ft.	Ft.	Gals/Hr.

Note : Although the best site for drilling has been suggested. NO GUARANTEE of success can be given and we will not be liable in any way for any loss to the party in respect of the well drilled at the recommended being failure.

AE-12

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಬಿಸಿ.ಎಂ ರಸ್ತೆ, ರವೀಂದ್ರನಗರ, ಬೆಂಗಳೂರು

Ravi. N.K.
A.E

RRA

(ARISH BABU R.R.)
Consultant Geologist / Diviner

ARISH BABU R.R. M.Sc.,

Jalashakthi Ground Water & Borewell Consultant

35/6, Kiran Complex, Opp. Mangalore Independent College,
Ullala Main Road, Muneshwara Nagar, Jnanabharathi Post,
Bangalore - 560 056.

Mobile : 99801 94377
98443 72004
E-mail : arishbabu11@gmail.com

GROUND WATER INVESTIGATION / YIELD REPORT

No.: KA/17/05/15

Date : 06/05/2017

Name & Adress : A.E.E. SHETTYHalli
W/12, SHETTYHalli Sub DIVISION
Bangalore

Purpose of Ground Water : Domestic (Drinking)

Ground Water Potential : Good

Site Location : Lingaha Badavane ARBitre

Topography : Plain Tessian

Soil : BROWNISH RED

Rock below the soil : Granite schist (metamorphic Rock)

Water Striking Levels					
	1st Source	2nd Source	3rd Source	Casing	Yield
Point # 1	480-500 Ft.	700-800 Ft.	950-1100 Ft.	180-190 Ft.	2100/2500 Gals/Hr.
Point # 2	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 3	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 4	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 5	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 6	Ft.	Ft.	Ft.	Ft.	Gals/Hr.

Note : Although the best site for drilling has been suggested. NO GUARANTEE of success can be given and we will not be liable in any way for any loss to the party in respect of the well drilled at the recommended being failure.

AEE-12

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಎಸ್.ಎಂ ರಸ್ತೆ, ರವೀಂದ್ರನಗರ, ಬೆಂಗಳೂರು

Ravi.N.K.
AE

RRA

(ARISH BABU R.R.)
Consultant Geologist / Diviner

ARISH BABU R.R. M.Sc.,

Jalashakthi Ground Water & Borewell Consultant

35/6, Kiran Complex, Opp. Mangalore Independent College,
Ullala Main Road, Muneshwara Nagar, Jnanabharathi Post,
Bangalore - 560 056.

Mobile : 99801 94377
98443 72004
E-mail : arishbabu11@gmail.com

GROUND WATER INVESTIGATION / YIELD REPORT

No.: KA/17/05/15

Date : 06/05/2017

Name & Adress : A.E.E. SHETTYHalli
W/12, SHETTYHalli SUBDIVISION
BANGALORE

Purpose of Ground Water : Domestic (Drinking)

Ground Water Potential : GOOD

Site Location : Vigneshwara layout SHETTYHalli

Topography : Plain Terrain

Soil : BROWNISH

Rock below the soil : GRANITIC Schist (Metamorphic Rock)

Water Striking Levels

	1st Source	2nd Source	3rd Source	Casing	Yield
Point # 1	400-500 Ft.	700-800 Ft.	950-1100 Ft.	190/210 Ft.	2100/2800 Gals/Hr.
Point # 2	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 3	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 4	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 5	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 6	Ft.	Ft.	Ft.	Ft.	Gals/Hr.

Note : Although the best site for drilling has been suggested. NO GUARANTEE of success can be given and we will not be liable in any way for any loss to the party in respect of the well drilled at the recommended being failure.

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ನಂ :೫
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ
ಎಸ್.ಎಂ ರಸ್ತೆ, ರವೀಂದ್ರನಗರ, ಬೆಂಗಳೂರು

Ravi N.K.
A.E

(ARISH BABU R.R.)
Consultant Geologist / Diviner

ARISH BABU R.R. M.Sc.,

Jalashakthi Ground Water & Borewell Consultant

35/6, Kiran Complex, Opp. Mangalore Independent College,
Ullala Main Road, Muneshwara Nagar, Jnanabharathi Post,
Bangalore - 560 056.

Mobile : 99801 94377
98443 72004
E-mail : arishbabu11@gmail.com

GROUND WATER INVESTIGATION / YIELD REPORT



No.: KA/17/05/15

Date : 06/05/2017

Name & Adress : A.F.E. SHETTYHALLI
D/12, SHETTYHALLI SUBDIVISION
BANGALORE

Purpose of Ground Water : Domestic (Drinking)

Ground Water Potential : GOOD

Site Location : Thamaiah Garden / ARBIGERE

Topography : Plain Terrian

Soil : BROWNISH RED

Rock below the soil : Granite Gneiss (Metamorphic Rock)

Water Striking Levels

	1st Source	2nd Source	3rd Source	Casing	Yield
Point # 1	500-600 Ft.	750-800 Ft.	950-1050 Ft.	180-190 Ft.	1900/200 Gals/Hr.
Point # 2	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 3	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 4	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 5	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 6	Ft.	Ft.	Ft.	Ft.	Gals/Hr.

Note : Although the best site for drilling has been suggested. NO GUARANTEE of success can be given and we will not be liable in any way for any loss to the party in respect of the well drilled at the recommended being failure.

AE-12

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರು
ಕೆಬ್ಬಿಹಳ್ಳ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಎಸ್.ಎಲ ಪಸ್ತೆ, ಬೆಂಗಳೂರು-56

M.K.
AE

PRA

(ARISH BABU R.R.)
Consultant Geologist / Diviner